



March 11, 2010

Michelle White
 MICHELLE WHITE & ASSOC.
 133 Roseann Drive
 RR 3
 Harrow, ON N0R 1G0

Bureau Veritas Work Order No. 10030543

Reference: 5203

Dear Michelle White:

Bureau Veritas North America, Inc. received 3 samples on 3/10/2010 for the analyses presented in the following report.

Enclosed is a copy of the Chain-of-Custody record, acknowledging receipt of these samples. Please note that any unused portion of the samples will be discarded 30 days after the date of this report, unless you have requested otherwise.

This material is confidential and is intended solely for the person to whom it is addressed. If this is received in error, please contact the number provided below.

We appreciate the opportunity to assist you. If you have any questions concerning this report, please contact a Client Services Representative at (800) 806-5887.

Sincerely,

Wendy Lesnik
 Client Services Representative

cc:

CASE NARRATIVE**Date: 11-Mar-10**

Client: MICHELLE WHITE & ASSOC.**Project: 5203****Work Order No 10030543**

The results of this report relate only to the samples listed in the body of this report.

Unless otherwise noted below, the following statements apply: 1) all samples were received in acceptable condition, 2) all quality control results associated with this sample set were within acceptable limits and/or do not adversely affect the reported results, and 3) the industrial hygiene results have not been blank corrected.

Bulk Asbestos Analysis:

Use of EPA/600/R-93/116 satisfies applicable requirements of the USEPA's "Interim Method for the Determination of Asbestos in Bulk Insulation Sample", EPA-600/M4-82-020, December 1982, published as Appendix E to Subpart E of 40CFR763.

Percentages are visual estimations. The reliable limit of quantitation of the method is 1%, although asbestos may be qualitatively detected at concentrations less than 1%. Samples for which asbestos is detected at <1% are reported as trace, "<1%". "None Detected" indicates that no asbestos fibers were observed.

ANALYTICAL RESULTS

Date: 11-Mar-10

Client: MICHELLE WHITE & ASSOC.

Client Reference: 5203

Work Order No.: 10030543

Sample Type: Bulk

Date Sampled: 03/09/2010

Method Reference EPA/600/R93/116

Date Received: 03/10/2010

Analyst: AJP

Date Analyzed: 03/11/2010

Lab ID	Sample Identification and Description (Layer and Morphology)	Asbestos Content (Percent and Type)	Non-asbestos Fibers (Percent and Type)	Non-fibrous Materials (Type)
001A	UW-B-14 (1) 100% Non-homogeneous Compressed Tan Mineral mixture (a) Note: See Case Narrative for Explanation	None Detected	< 1% Cellulose fiber	Binder/Filler Vermiculite
002A	UW-B10-316 (1) 100% Non-homogeneous Non-compressed Tan Fiber and mineral mixture	None Detected	35% Cellulose fiber	Binder/Filler
003A	UW-316 (1) 100% Non-homogeneous Non-compressed Gray Mineral mixture	None Detected	< 1% Cellulose fiber	Binder/Filler